

NC203A

fixing clip @ 600 centers

Drained and vented cavity as per E2/AS1

Wall underlay folded into opening

Flexible flashing tape over flashing upstand

2.8x50mm hot dipped galvanised clout nails
in to framing @ 600 centers.
(SS for Exposure Zone D)16mm H3.2 timber head-batten
*See note**NC226**

Impervious barrier between batten & cladding

Cavity closer as per E2/AS1 (By others)

NC101

Starter strip

5mm min gap

10mm min cover

Sealant for Very High to Extra High
wind zones.**NC227**Plastic soaker flashing behind jamb.
Flashing base extends down into
channel on immediate board below**NOTE 1:**Rigid Air Barrier (RAB) also required in
Extra High wind zones. Refer to E2/AS1
(section 9.1.7.2)**NOTE 2:**Detail depicts use of starter strip to
locate a full board. Refer to NW-HOC-
020 where a notched board occurs**General note:**

- Cladding fixings omitted for clarity

Window setting out notes:

- 17-18mm for hollow fin windows
- 18-20mm for solid fin windows

Cavity batten note:

- 20mm single castellated timber battens required for all Nu-Wall installations.
- Batten to have 15° slope for moisture egress
- Allow 6mm gap between vertical and horizontal battens
- Sill and head battens to be max. 500mm with a 6mm gap to each segment
- 18mm single castellated battens are available from Nu Wall for all vertical applications to wall junctions and jambs
- Proprietary Nu-Wall Alibat is available as an alternative when a structural non-combustable cavity batten is required

Interactive assembly
instructions available
<http://wkspec.nz/nw-hoc-win>Get WORKINGSPEC from
Apple App Store/Google PlayStop-end tabbed up on both
sides of head flashing**nu-wall**
CLADDING

Nu-Wall cladding horizontal on cavity

Typical head section - full board using NC101 starter

© 2021 copyright in this document is the property of Nu-Wall Aluminium Cladding Limited. All rights reserved. Nu-Wall is a registered trademark of Aluminium Product Brands NZ Limited

NW-HOC-017.02

Drawn by: Nu-Wall

Date: 02/07/2025

Checked by: RL, GT

Scale: 1:2 @ A4

BRANZ Appraised
Appraisal No. 550