



**Note:**  
Corner battens trimmed and notched to accommodate flashing build-up

Wall underlay continuous around corner

2.8x50mm hot dipped galvanised clout nails @ 600 centers.  
(SS for Exposure Zone D)

**NC226**  
Impervious barrier between batten & cladding

**NC247T + NC248**  
Termination flashing base and cap.

15mm profiled closed cell foam insert end caps to suit profile of cladding

**NC204**  
10g ss pan head screws with 30mm min embedment

**NC203A**  
fixing clip @ 600 centers

**General note:**

- Cladding fixings omitted for clarity
- When finishing a wall with a ripped board, the board must be direct fixed with a counter sunk screw @ 600mm centres

**Cavity batten note:**

- 20mm single castellated timber battens required for all Nu-Wall installations.
- Batten to have 15° slope for moisture egress
- Allow 6mm gap between vertical and horizontal battens
- Sill and head battens to be max. 500mm with a 6mm gap to each segment
- 18mm single castellated battens are available from Nu Wall for all vertical applications to wall junctions and jambs
- Proprietary Nu-Wall Alibat is available as an alternative when a structural non-combustable cavity batten is required



**nu-wall**  
CLADDING

Nu-Wall cladding horizontal on cavity

Typical Nu-Wall irregular internal corner flashing

NW-HOC-040.03

Drawn by: Nu-Wall

Date: 02/07/2025

Checked by: RL, GT

Scale: 1:2 @ A4

© 2021 copyright in this document is the property of Nu-Wall Aluminium Cladding Limited. All rights reserved. Nu-Wall is a registered trademark of Aluminium Product Brands NZ Limited